

Government of Bihar
Public Health Engineering Department

DISTRICT :- SAMASTIPUR		DIVISION :- SAMASTIPUR										MONTH:-MARCH 2026			
S.N.	BLOCK	LOCATION OF SOURCE	PARAMETERS										REMARKS		
			pH	TURB	EC	TDS	TH	Ca	Cl	Mg	Alka.	Fe			
1	ROSERA	BIRLA OPEN MINDS INTERNATIONAL SCHOOL SAHIYAR BURJ ROSERA	7.1	1	123	80	46	22	26	12	52	0.1	-ve		
Acceptable Limit as per BIS 10500/2012			6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	250mg/l	30 mg/l	200 mg/l	1.0mg/l			
Permissible Limit* in Absence of Alternate source as per BIS 10500/2012			NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	1000 mg/l	100 mg/l	600 mg/l	NR			

Som
10/03/26
Chemical Lab Assistant
P.H.E. Division Samastipur
P.H.D. Laboratory
Samastipur

SAFE DRINKING WATER AND SANITARY

CONDITION CERTIFICATE

No....130.....

Date...10/03/26.....

It is Certified that an Inspection team headed by **RAMBRIKASH BAITHA**, **ASSISTANT ENGINEER, P.H.E.D Samastipur** from **Public Health Division, Samastipur** inspected the **BIRLA OPEN MINDS INTERNATIONAL SCHOOL, SINGHIA BUJURG ROSERA MUBBI ROAD SAMASTIPUR** On 10.01.2026 and found that the school **BIRLA OPEN MINDS INTERNATIONAL SCHOOL** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/state/U.T.Govt.


Signature with seal: 10.03.26 अवर प्रमंडल पदाधिकारी
ब्लॉक स्टा० अवर प्रमंडल
रोसड़ा

Name: ... **RAMBRIKASH BAITHA**

Designation: **ASSISTANT ENGINEER**

To,

Principal,

BIRLA OPEN MINDS INTERNATIONAL SCHOOL

SINGHIA BUJURG ROSERA MUBBI ROAD SAMASTIPUR

(Name & Address for the institution)